

Kuivatites kasutatavad ventilaatorid



Tüüp	Võimsus (kW)	Pinge (V)	Vool (A)	Pöörete arv (x/min)	Õhukogus (m ³ /h)	Surve max Pa	Kaal (kg)	Mürategur (dB)	Töötemperatuur (C)	IP kaitseaste
500/SU/8 = 8/50/400	0.55	400V	1.35	1400	8870	180	15	82	-20 +100	IP 56
600/SU/8 = 8/50/400	0.9	400V	2.3	1400	14100	220	22	86	-20 +100	IP 56
700/SU/12-12/50/400 0	2.2	400V	5.2	1400	22100	330	33	90	-20 +100	IP 56
800/SU/9 = 9/45/400	3.3	400V	7.1	1450	30500	6800	48	89	-20 +100	IP 55
900/SU/9 = 9/40/400	3.3	400V	7.1	1450	33800	6500	51	87	-20 +100	IP 55